

Jeffrey A. Iveson  
Water Commissioner, Village of Delanson  
1797 Main Street, PO Box 235  
Delanson, New York 12053

---

**Period of October 1, 2014 – October 31, 2014**

Total Amount of Water Used per Period:	994,000 gals.
Average Amount of Water Used per Day:	32,000 gals.
Total Amount of Hypochlorite Used per Period:	41 gals.
Average Amount of Hypochlorite Used per Day:	1.32 gals.

Wednesday, October 1, 2014:

- \* Sent monthly operational reports to Schenectady Co. DOH
- \* Emailed monthly report to Board to Village Clerk
- \* Responded to Dig Safely request by phone @ 5:16PM (811 call system does not work)
- \* Met with Gayle to discuss billing for breaks and lower spillway FEMA work

Tuesday, October 6, 2014:

- \* Attended Village Board meeting

Saturday, October 11, 2014:

- \* Steve and I completed FEMA work on spillway at Lower Reservoir
- \* Steve and I installed light on power pole and installed bollards at the plant

Monday, October 13, 2014:

- \* Draining down filter bed#2

Tuesday, October 14, 2014:

- \* Steve and I cleaned filter bed #2

Monday, October 20, 2014:

- \* Ordered UV bulbs
- \* Responded to Dig Safely request at property on Duanesburg Churches Rd.

Tuesday, October 21, 2014:

- \* Provided Gayle with guidelines for residents during/after water main main breaks

Thursday, October 23, 2014:

- \* Responded to Dig Safely request from NYS DOT for sign installation on Rte. 20

Tuesday, October 28, 2014:

- \* Installed two lights at the plant. One over the entry door and one behind the plant

Wednesday, October 29, 2014:

- \* Telephone conversation with Gayle regarding materials and labor costs for the spillway and FEMA project costs

---

**THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED BY FEDERAL LAW. COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF CIVIL RIGHTS, ROOM 326W, WHITTEN BUILDING, 14<sup>TH</sup> & INDEPENDENCE AVE. SW, WASHINGTON, D.C. 202500410 (518) 895-2100 TDD# 1-800-662-1220**