

Jeffrey A. Iveson
Water Commissioner, Village of Delanson
1797 Main St. PO box 235
Delanson, New York 12053

Period of July 1, 2022 – July 31, 2022

Total Amount of Water Used per Period:	1,415,000 gals.
Average Amount of Water Used per Day:	46,000 gals.
Total Amount of Hypochlorite Used per Period:	41.75 gals.
Average Amount of Hypochlorite Used per Day:	1.34 gals.

Monday, July 11th, 2022:

- Attend village board meeting.

Wednesday, July 13th, 2022:

- Cleaned filter bed #3

Thursday, July 14th, 2022:

- Have been working with new assistant water comm. at the water filtration plant. I have been training him on daily sampling and recording.

Friday, July 15th, 2022:

- Notified Schenectady health department that the village has hired a assistant water comm. Also notified that the new assistant will be working under my water license and is in training until next year.

Thursday July 28th, 2022:

- Sent monthly Bac-T, Soc, Voc, into JH lab.

**THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED.
COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF
CIVIL RIGHTS, ROOM 326W, WHITTEN BUILDING, 14TH & INDEPENDENCE AVE. SW,
WASHINGTON, DC 202500410 (518) 895-2100 TDD#3 1-800-662-1220**