

Jeffrey A. Iveson
Water Commissioner, Village of Delanson
1797 Main St. PO box 235
Delanson, New York 12053

Period of August 1, 2022 – August 31, 2022

Total Amount of Water Used per Period:	1,415,000 gals.
Average Amount of Water Used per Day:	46,000 gals.
Total Amount of Hypochlorite Used per Period:	41.75 gals.
Average Amount of Hypochlorite Used per Day:	1.34 gals.

Thursday, August 4th, 2022:

- Received test results from SOC. VOC, and monthly Bac-T

Wednesday, August 10th, 2022;

- Received a call from a village resident on the corner of Stewart Drive and 395 (Tarmy's on residence) to locate a shut off.

Thursday, August 11th, 2022:

- Cleaned filter bed #3

Saturday August 13th, 2022:

- Flushed hydrants also while flushing hydrants we cleaned and painted the Ballard's at the water filtration plant by the corner of the building and propane tanks.
- Cleaned and painted the Ballard's on the corner of 395 and Cole road by the fire hydrants.
- Cleaned and painted the Ballard's on thousand acre rd. on village line and Elm Street by the fire hydrant.
- *NOTE fire hydrant stem on the end of Railroad Ave near harvest homes broke, and the hydrant is inoperable.

Monday August 15th, 2022

- Took monthly Bac-T samples, THM and HA5 samples.
- 4 mark out request from dig safely from national grid for, 4 telephone replacements.

Tuesday August 16th, 2022

- Received total chloroform results back from J&H.

Wednesday August 17th, 2022

- Received IOC/ VOC results back.

Monday August 29th, 2022

- Received gross alpha results back.

Wednesday August 31, 2022

- Received email from J&H consulting on approved sand bids for sand replacements.
-

**THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED.
COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF
CIVIL RIGHTS, ROOM 326W, WHITTEN BUILDING, 14TH & INDEPENDENCE AVE. SW,
WASHINGTON, DC 202500410 (518) 895-2100 TDD#3 1-800-662-1220**