

Jeffrey A. Iveson  
Water Commissioner, Village of Delanson  
1797 Main St. P.O. Box 235  
Delanson, New York 12953

---

**Period of December 1st, to December 31, 2022**

Total Amount of Water Used per Period: 2,097,000  
Average Amount of Water Used per Day: 68,000  
Total Amount of Hypochlorite Used per Period: 28 Gal  
Average Amount of Hypochlorite Used per Day: .90 Gal

Thursday December 1st

- Received a message from the clerk that Hyde residence on East Shore Rd has low water pressure.

Monday December 5th

- Spoke with a resident on 1738 Main street concerning low water pressure and discolored water. I visited the residence to find out that the toilet tank flap needed to be replaced and was continuously leaking.
- Responded to the Hyde Residence on East Shore rd for the 2<sup>nd</sup> time. I spoke to the resident living there and asked them to call me and there was still no response.

Wednesday December 7<sup>th</sup>

- Ordered UV bulbs for the filtration plant. I notified the clerk that they were on order

Friday December 9<sup>th</sup>

- UV bulbs came in.

Wednesday December 14<sup>th</sup>

- Mesick residence called to have the water service turned off, came in office to fill out application.

Tuesday December 27<sup>th</sup>

- Found 168 Stewart drive had to turn the water off at the residence.

Wednesday December 28<sup>th</sup>

- Cleaned filter bed #3

Thursday December 29<sup>th</sup>

- Located the break on East Shore rd, and repaired it.
- Turned the water back on at 168 Stewart Drive, and will revisit site to check service line for leak.

**THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED.. COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF CIVIL RIGHTS, ROOM 326W, WHITTEN BUILDING, 14<sup>TH</sup> & INDEPENDENCE AVE. SW, WASHINGTON, D.C. 202500410 (518) 895-2100 202500410 (518) 895-2100 TDD# 1-800-662-1220**