

Jeffrey A. Iveson  
Water Commissioner, Village of Delanson  
1797 Main St. P.O. Box 235  
Delanson, New York 12053

---

**Period of February 1, 2024 – January 29, 2024**

Total Amount of Water Used per Period:	835,000gals.
Average Amount of Water Used per Day:	29,000 gals.
Total Amount of Hypochlorite Used per Period:	21.5 gals.
Average Amount of Hypochlorite Used per Day:	.74 gal

Saturday, February 3, 2024:

- Re-sand filter bed #3

Saturday February 10, 2024:

- Re-sand filter bed 2.
- 

Monday ,February 12, 2024:

- Called Seward sand and gravel to order the rest of sand for filter beds
- 

Friday February 16, 2024:

- Cleaned filter bed 1.

Saturday February 17, 2024:

- Re-sand filter bed 1
- Call carver to discuss bills and applying portions of rd repair to chips

Thursday February 22, 2024:

- Responded to Rt. 395 received a call about dead deer over the bank along the rd near reservoir,met with the sheriff there,they called encon officer.
- 

Monday February 28, 2024:

- Respond to dig safe request to 428 east shore rd

Friday, January 30, 2024:

- Found the 4<sup>th</sup> water break on East Shore Rd and Main Street, I called carver and updated the website again.
- Called DOT and Schenectady highway, notified of break on Main Street.

Saturday, January 31, 2024:

- Scheduled carver to pour concrete on Main Street for a break repair.

---

**THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED.  
COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF  
CIVIL RIGHTS, ROOM 326W, WHITTEN BUILDING, 14<sup>TH</sup> & INDEPENDENCE AVE. SW,  
WASHINGTON, D.C. 202500410 (518)895-2100 YDD# 1-800-662-1220**