Period of January 1, 2024 – January 31, 2024

Total Amount of Water Used per Period: Average Amount of Water Used per Day: Total Amount of Hypochlorite Used per Period: Average Amount of Hypochlorite Used per Day: 2,461,000gals. 82,000 gals. 33 gals. 1.06 gal

Saturday, January 6, 2024:

• Cleaned filter bed number 1

Thursday January 11, 2024:

- Cleaned filter bed number 1.
- Marked out water break leak on East shore Rd. 3/4" Service line broke, called carver to repair leak.

Friday, January 12, 2024:

- Called dig safe
- Carver repaired ³/₄" service line on East Shore Rd.

Monday, January 15, 2024:

• Located another water main break, there were several low water complaints.

Thursday, January 25, 2024:

- Called Dig safe
- Started digging water leak on Cole rd and 395. Rural water used the correlator to help pin point the break. Dug through the night and into the next day. Found the break on east side of 395. I located and repaired the leak.

Friday, January 26, 2024:

- While fixing the water break, I also repaired the sewer main as proper separation of pipes was not accomplished at the time of sewer installation. I notified the sewer department.
- Finished the water main repair and found another break, 68' away on the west side of 395. I called carver to repair that break.

Tuesday, January 27, 2024:

• Updated village website.

Thursday, January 29, 2024:

- Called A-1 water, had 27,000 gals of water delivered.
- Received back flow preventer reports from school.

Friday, January 30, 2024:

- Found the 4th water break on East Shore Rd and Main Street, I called carver and updated the website again.
- Called DOT and Schenectady highway, notified of break on Main Street.

Saturday, January 31, 2024:

• Scheduled carver to pour concrete on Main Street for a break repair.

THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED. COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE IF CIVIL RIGHTS, ROOM 326W, WHITTEN BUILDING. 14TH & INDEPENDENCE AVE. SW, WASHINGTON, D.C. 202500410 (518)895-2100 YDD# 1-800-662-1220