

Jeffrey A. Iveson
Water Commissioner, Village of Delanson
1797 Main St. P.O. Box 235
Delanson, New York 12053

Period of March 1, 2024 – March 31, 2024

Total Amount of Water Used per Period:	842,000gals.
Average Amount of Water Used per Day:	27,000 gals.
Total Amount of Hypochlorite Used per Period:	21 gals.
Average Amount of Hypochlorite Used per Day:	.67 gal

Monday, March 4, 2024:

- Respond to dig safe mark out request 428 east shore rd

Friday March 8, 2024:

- Received 1st quarter Thm – Ha5 results from Jh lab

Monday, March 18, 2024:

- Respond to dig safe request, Duanesburg churches rd.
-

Wednesday March 20, 2024:

- Completed annual quality water report and returned it to the lab as well as monthly water sample

Monday March 25, 2024:

- Respond to 3 dig safe tickets from Rifenburg construction for rt.395
- Received a call from harvest homes no water? Responded They determined they had frozen water pipes in their office.

**THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED.
COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF
CIVIL RIGHTS, ROOM 326W, WHITTEN BUILDING. 14TH & INDEPENDENCE AVE. SW,
WASHINGTON, D.C. 202500410 (518)895-2100 YDD# 1-800-662-1220**